

VOC Content Test Certificate

Wednesday May 21st, 2008

Manufacturer: Conceal Concrete Waterproofing

PO Box 239

Campelltown NSW 2560

Sample Description: Aussietex III waterproofing membrane

Date Tested: May 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ -13 Green Star Office Design V3 IEQ-13 Green Star Office Interiors V1.1 IEQ -11	Aussietex III
Architectural Sealant 250 grams per Litre	14 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0805-66